

Tel: (011) 805-5002
Fax: (011) 805-5033

The AAAMSA Performance Test Certificate



Postal Address:
PO Box 7861
Halfway House, 1685

(for inclusion with Forms 1 and 4 of SANS 10400-A)

NOT TRANSFERABLE

Section A: Particulars of Applicant

Applicant:

Origin Aluminium
PO Box 20971
Durban North
4016

Certificate
Number

D434

Section B: Description of sample submitted for testing

AAAMSA Class Designation:

A3

Applicants' Drawing Reference:

340-CM1 REV A

Product

Origin 340 Casement window

Overall Dimensions:

1200mm wide x 1200mm high

Glass Type:

Glass Thickness:

4mm Clear float

Glazing Gaskets:

PVC

Weather Seals:

Bubble Seal/Fin File


Hardware:

Standard

Joint Sealant:

Silicone

Dimensional Sketch of Sample



Comments by Testing Authority

Notes:

Section C: Testing

NOT TRANSFERABLE

Performance Test	Test Conditions	Measured Result	Allowed Result
1. Air Infiltration	75 Pa	,01l/sec/m ²	0,75l/sec/m ²
2. Positive Pressure	2000 Pa	2,5 mm	6,6 mm
3. Negative Pressure	2000 Pa	2,4 mm	6,6 mm
4. Water Penetration	400 Pa	No Leaks *	No Leaks
5. Structural Pressure	3000 Pa	No permanent deformation	No Permanent deformation
6. Operating Forces: To start movement To sustain Movement			

Section C: Testing

Testing Authority:

(Stamp) R Saunderson PEng.
Reg. No. 703219

Validated by AAAMSA:

(Stamp) AAAMSA
PO Box 7861
Halfway House, 1685

Date of issue: 5 April 2007

Date of Validation: 13 April 2007

Signed: Mr. R Saunderson

Signed:

Designation: Testing Officer

Designation: Executive Director